

Transformer Condition Assessment TCA TM

Todd Energy
95 Customhouse Quay
Wellington, New Zealand

Location: Todd Energy
Bank & Phase: TAW T1
Serial Number: 31G3932/1
Manufacturer: GEC Alstom
Date Mfgd: 1995
Voltage Ratio (kV): 11/110
Rating (MVA): 28

Date: 28/08/12
Report Number: **6078656**
Order Number:
Fluid volume: 20625 L
Fluid type: Mineral Oil
Breathing: Free
Cooling: ONAN
Core & coil wt: 38400kg

Sample Receipt Date: 08/08/12
Sample Date: 27/07/12
Laboratory No.: 6078656
Container No.
Temperature: 12

ASTM D3612-PartA

H2	Hydrogen	(ppm):	203
CH4	Methane	(ppm):	25
C2H6	Ethane	(ppm):	<1
C2H4	Ethylene	(ppm):	12
C2H2	Acetylene	(ppm):	<1
CO	Carbon monoxide	(ppm):	386
CO2	Carbon dioxide	(ppm):	1492
N2	Nitrogen	(ppm):	54408
O2	Oxygen	(ppm):	13772

Dissolved Gas Analysis results. Enables detection of faults such as Partial Discharge, Heating or Arcing. Also, CO & CO2 levels and ratios provide an indication on whether abnormal paper degradation is occurring.

Total (ppm): **70298** = Total Gas Concentration.
TDCG (ppm): **626** = Total Dissolved Combustible Gases
SHL (%): **5.72** = Safe Handling Limit in terms of combustible Gas levels in headspace
ETCG (% in blanket): **1.02** = Estimated Total Combustible Gases in headspace. If ETCG is greater than SHL, then precautions must be taken when handling fluid such as sparging with Nitrogen

Particles(Counts/100mL)	5 to 15 um:	57405
Particles(Counts/100mL)	15 to 25 um:	3070
Particles(Counts/100mL)	25 to 50 um:	465
Particles(Counts/100mL)	50 to 100 um:	35
Particles(Counts/100mL)	>100 um:	0

Particle Count detects activity such as fluid & paper degradation, rust formation, mechanical wear & coke formation.

D1533	Moisture	(ppm):	9
IEC 156	Dielectric BV	(kV):	63
D974	Acid Number	(mg KOH/g):	<0.01
D971	Interfacial Tension	(mN/m):	43.1
D1500	Color Number	:	<1.5
IEC 247	Dielectric Dissipation Factor	(% at 25C):	0.035
D2668	Oxidation Inhibitor	(%w/w):	0.30

Oil Quality parameters which have a direct bearing on transformer life or in extreme cases can lead directly to failure (eg. flashover from excessive moisture or sludge formation from high acid).

5 HMF	5 hydroxymethyl-2-furaldehyde	(ppm):	<0.001
2 FAL	2 furaldehyde	(ppm):	0.005
2 ACF	2-acetylifuran	(ppm):	<0.001
5 MEF	5 methyl-2-furaldehyde	(ppm):	<0.001
2 FOL	2 furfural	(ppm):	<0.001

Furanic compound concentrations in oil which come from paper degradation. These values are used to calculate the Estimated Ave. Degree of Polymerization of the paper.

Estimated Ave. Degree of Polymerization : **>1000** This is calculated from the above Furan levels
TCA Assessment **2**

Transformer Condition Assessment Diagnostic Evaluation

TCA Assessment: 2 = Condition code which can be 1, 2, 3, 4 or 4* (1 = best, 4/4* = worst)

Sampling Interval: Retest in six months. Establish trends and confirm condition

Operating Procedure: Continue normal operation.

Comments: Partial discharge is indicated.

Field Comments: Fluid condition is within acceptable in-service parameters.
Paper condition is "as new" (based on furan levels).

The condition code is based on the relationship between all the parameters tested. An elevated code can be triggered by abnormal levels of a single parameter or by any combination of numerous abnormal results.

Authorised by: Frank Catela